

ADDENDUM NO. 6

DATE: 10/19/2022

TO: ALL PROSPECTIVE BIDDERS

SUBJECT: Solicitation No. AA005A

TITLE: E SATELLITE AND LOWER CONCOURSE E STUCCO REPLACEMENT, PAINT, LIGHTNING PROTECTION, ADVANCED VISUAL DOCKING GUIDANCE SYSTEM (AVDGS), CAMERAS, DOORS/HARDWARE/ACCESS CONTROL

This Addendum becomes a part of the subject solicitation.

- A. The Solicitation End Date has been extended to October 28, 2022, 2:00 PM Local Time.
- B. The following attachments are hereby replaced in their entirety with the revised Specs and Drawings are attached to this Addendum:
 - Attachment A REVISED AA005A BULLETIN 002 SPEC
 - Attachment B REVISED AA005A BULLETIN 002 DRWGS
- C. The following questions were received:

Question No. 1

Reference Dwg E720, Symbol (t), which specifies "COAXIAL VIDEO CABLE" for the CCTV cameras. Please confirm cable type.

Answer No. 1

There will be no coax cabling on this project. Only CAT 6 cabling is to be used throughout this project. Disregard the words "COAX cabling" throughout the bid document and wherever you see the word COAX replace it with CAT 6.

Question No. 2

Please provide specifications for Intercom Headend equipment.

Answer No. 2

Intercom Headend equipment is furnished by Project Network to include integration and provided by CNP, which is the MDAD Airport integrator as listed in Section 1 of the solicitation. Please see solicitation for contact details.

Question No. 3

Please confirm the temporary doors shown on the door schedule (Dwg AN501.02) do not require any Card Access/CCTV system per MDAD guidelines

Answer No. 3

Temporary doors are meant to be in place for a very short period of time. Therefore, no card readers should be installed for these temporary doors. Contractor to coordinate the construction work with MDAD facilities, Operations, and the Fire Department to assure emergency egress is maintained at all times. Reference approved construction contract documents for



designed door hardware for these temporary doors.

All other information remains the same.

Miami-Dade County,

Caroline Burgos Senior Procurement Contracting Officer

c: Clerk of the Board